


SECTION - Through A-A

**PLAN** 









Damage caused by incorrect lifting is the responsibility of others

## Notes:

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at
- · Specify any specific requirements prior to ordering. All civil works by customer
- · Do not scale from this drawing. Only for illustration purposes



Clara Rd., Tullamore, Co. Offaly T: 057 9326000 E: info@molloyprecast.com F: 057 9326060 W: www.molloyprecast.com











Title: NSB06 by-pass interceptor, EN858 Class 1

Drg. no.: NSB03-HH-130818

Nominal flow: 3 l/s

Peak flow: 30 l/s

Area coverage: 1,666 sq. m

Max. silt capacity: 1,600 litres

Max. emergency oil retention: 320 litres

Date: 25/07/2018

Drawn by: SF Checked by: