


SECTION

Interceptor tank







Damage caused by incorrect lifting is the responsibility of others

Notes:

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at
- Specify any specific requirements prior to ordering. All civil works by customer
- Do not scale from this drawing. Only for illustration purposes

Title: NSB40 by-pass interceptor, EN858 Class 1

Drg. no.: NSB40-2S+-010219

Nominal flow: 40 l/s

Peak flow: 400 l/s

Area coverage: 22,222 sq. m

Max. silt capacity: 4,850 litres

Max. emergency oil retention: 1,200 litres Date: 01/02/2019

Drawn by: KR Checked by: MC, SF, OM