


110mm vent to vent stack (by others). It is recommended this stack should be 4-5m high or as per site engineers recommendations


160mm Inlet



MOLLOY
ENVIRONMENTAL SYSTEMS
 Clara Rd., Tullamore, Co. Offaly
 T: 057 9326000 E: info@molloyprecast.com
 F: 057 9326060 W: www.molloyprecast.com



Tank lifting limitations:
 Max chain angle <math>< 60^\circ</math>



Damage caused by
 incorrect lifting is the
 responsibility of others

Notes:

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at any time
- Specify any specific requirements prior to ordering. All civil works by customer
- Do not scale from this drawing. Only for illustration purposes

Title: L tank pump station

Volume: 10,000 litres

Usable volume: 7,100 litres

Drng. no.: PS-L-063-120520

Date: 12/05/2020

Drawn by: SF