


Tank lifting limitations:
Max chain angle < 60°



Damage caused by incorrect lifting is the responsibility of others

Notes:

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at any time
- Specify any specific requirements prior to ordering. All civil works by customer
- Do not scale from this drawing. Only for illustration purposes
- Rainwater from roofs only
- Manhole chamber and pipework by others (marked in grey)
- Risers by contractor or as required
- Optional mains-part-fill-make-up-valve in header or RWH tank (BS8515 compliant with >36mm AA air gap)
- Float switches must be installed at heights as per this drawing
- Rainwater input from roofs only



Clara Rd., Tullamore, Co. Offaly
T: 057 9326000 E: info@mollyprecast.com
F: 057 9326060 W: www.mollyprecast.com



Title: 7,000L Rainwater Harvesting System
 Drg. no.: RW-1S+-GEP-001-190719
 Tank Volume: 7,000L
 Rainwater Storage: 5,700L
 Date: 19/07/2019
 Drawn by: KR Checked by: